

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Spills that Entered Waters of the US/State

SSO NO.	Date/Time		Type & Volume			Location		MH/Line		Cause/Source		Water Body		Flow Restoration			Notification Dates			Update Comments
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole/Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up	Comments
43	4/3/2013	12:09	n		4,305	2100 Winterspark Drive	Doraville	340-s008	8	GRRT	Grease and roots blocked main	Nancy Creek	2	4/3/2013	12:50	Pressure washed 8 inch main 350 feet to clear grease blockage and restore flow.	04/04/13	04/04/13	CCTV 450 feet and found light grease in the line which was removed.	
44	4/6/2013	9:40	n		1,360	1116 Nielson Drive	Clarkston	095-s011	8	GRRT	Grease and roots blocked main causing cleanout to overflow.	Snapfinger Creek	C	4/6/2013	10:48	Rodded main 15 feet without success. Pressure washed main 120 feet and cleared blockage at 15 feet.	04/06/13	04/08/13	CCTV 630 to find roots and grease which were removed.	Added waterbody name to 5 day notice.
45	4/8/2013	7:39	n		7,800	2737 Winding Lane	Atlanta	242-s019	8	RT	Roots blocked 8 inch main causing spill from manhole	North Fork Peachtree Creek	A	4/8/2013	9:49	Rodded and pressure washed 250 feet of main to restore flow.	04/08/13	04/09/13		
46	4/8/2013	17:40	n		1,830	1920 Apache Trail	Atlanta	085-s120	8	GRDB	Grease and debris blocked line causing broken cleanout to overflow	Sugar Creek	U	4/8/2013	18:30	Rodded main 75 feet to restore flow and pressure washed 350 feet to clean immediate area.	04/09/13	04/09/13	Cleanout repaired 5-21-13	
47	4/9/2013	9:12	n		2,400	3423 Tulip Drive	Decatur	187-s096	8	GR	Grease blocked 8 inch main	Cobbs Creek	N	4/9/2013	9:52	Pressure washed 8 inch main upstream 80 feet to remove blockage and restore flow and downstream 520 feet.	04/15/13	04/16/13		Employee error delayed reporting.
48	4/10/2013	12:05	n		4,440	6615 Tribble Street	Lithonia	121-s061	8	GR	Grease blocked line and manhole.	Pole Bridge Creek	U	4/10/2013	13:19	Rodded line 3 feet to restore flow followed by pressure washing 614 feet to remove grease in area.	04/11/13	04/11/13		
49	4/11/2013	7:57	n		5,790	56 Perimeter Center East	Dunwoody	347-s021	12	GR	Grease blocked sewer main	North Fork Nancy Creek	U	4/11/2013	11:10	Pressure washed 12 inch main 20 feet to restore flow followed by pressure washing 50 feet of 12 inch main.	04/11/13	04/12/13		
50	4/15/2013	14:39	n		2,400	3593 Buford Highway	Atlanta	203-s323	8	GRDB	Grease and sticks blocked 8 inch main	North Fork Nancy Creek	A	4/15/2013	15:39	Pressure washed 8 inch line 50 feet to remove blockage at 25 feet and restore flow.	04/16/13	04/16/13		
51	4/17/2013	14:27	n		3,600	2245 Perimeter Park Drive	Chamblee	334-s109	8	GRRT	Grease and roots blocked 8 inch main.	Nancy Creek	U	4/17/2013	15:57	Rodded main 200 feet but could not restore flow. Pressure washed main 644 feet to remove blockage at 120 feet and restore flow.	04/18/13	04/18/13		Correct address is 2245 not 2249 as noted in 5 day letter.
52	4/20/2013	22:04	n		4,980	3555 Lawrenceville Highway	Tucker	187-s108	8	GR	Grease blocked 8 inch main.	South Fork Peachtree Creek	A	4/20/2013	23:27	Pressure washed from manhole to manhole for 271 feet to remove grease blockage at 220 feet.	04/21/13	04/22/13		
53	4/23/2013	16:38	n		5,280	4964 Fairforest Drive	Stone Mountain	017-s072	8	RTDB	Roots and debris blocked 8 inch main.	Barbashela Creek	UL	4/23/2013	18:50	Rodded main 123 upstream from MH# 017-s088 to restore flow. Pressure washed 520 upstream from same manhole.	04/24/13	04/24/13	Cause changed from grease to roots upon investigation.	
54	4/25/2013	9:52	n		2,000	1364 Church Street	Decatur	007-s123	8	GR	Grease blocked 8 inch main	Church Street Branch of South Fork Peachtree Creek	Y	4/25/2013	10:42	Rodded from 007-s211 upstream 69 feet and restored flow.	04/25/13	04/26/13		
55	4/30/2013	8:34	n		345	2665 Johnson Street	Lithonia	152-s008	8	GR	Grease blocked 8 inch main.	Honey Creek	N	4/30/2013	9:43	Rodded 8 inch main 180 feet to restore flow and then pressure washed 300 feet to clean line.	04/30/13	05/01/13		
56	5/2/2013	11:57	n	YES	337,902	4347 Flat Shoals Parkway	Decatur	NA	30	BRK LN/STR	30 by 30 steel line top caved in from corrosion and spilled in creek.	Cobbs Creek	N	5/3/2013	4:15	Diverted flow from creek crossing into overflow line inside MH 15-070-s050	05/03/13	05/03/13	Abandoned old creek crossing and used new overflow line. Old line being removed.	
57	5/3/2013	9:42	n	YES	48,200	4867 Ashford Dunwoody Road	Dunwoody	363-s017	10	GRDB	Line blocked with grease and rags	North Fork Nancy Creek	N	5/3/2013	17:44	Bypass pump used to control flow. Buried manhole prevented pressure washing the blocked segment. CCTV revealed problem and once exposed line was cleaned the next day.	05/04/13	05/06/13		
58	5/4/2013	18:37	n	YES	51,050	454 Superior Avenue	Decatur	051-s117	16	OTH	Heavy flow during storm entered into a reduced size segment of line (16 to 12)	South Fork Peachtree Creek	Y	5/5/2013	11:38	Waited for rain to subside.	05/05/13	05/06/13	Major project was underway on this line issue.	

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Spills that Entered Waters of the US/State

SSO NO.	Date/Time		Type & Volume			Location		MH/Line		Cause/Source		Water Body			Flow Restoration			Notification Dates			Update Comments
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole/Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up	Comments	
59	5/5/2013	0:03	n		6,400	101 Green Street	Decatur	214-s003	8	STORM	Heavy rain in area flooded streets and inundated line.	Shoal Creek	W	5/5/2013	2:11	Waited for rain to subside.	05/05/13	05/06/13	Area under previous investigation. County made some upgrades and waiting on Decatur to clear their storm drains. Smoke test found some defects and roof drains tied into system. Defects repaired so far have helped with inflow reduction during rain events..		
60	5/5/2013	15:22	n		5,400	5139 North Peachtree Road	Dunwoody	NA	8	GR	Grease blocked 8 inch main	Leisure Lake	L	5/5/2013	16:56	Pressure washed 300 feet and cleared the grease blockage.	05/06/13	05/06/13	Grease blockage revealed a line defect. Line is also flat.		
61	5/5/2013	20:03	n		8,890	2358 Tristan Circle	Atlanta	207-s047	10	DB	Debris ???? blocked 10 inch line.	North Fork Peachtree Creek	Y	5/5/2013	22:10	Pressure washed main 300 feet to remove blockage and restore flow.	05/06/13	05/06/13			
62	5/7/2013	15:26	n	YES	80,215	801 Briar Park Court	Atlanta	NA	24	CRK BRK	Fallen tree broke 24 inch main in creek crossing.	South Fork Peachtree Creek	N	5/7/2013	19:49	Line bypassed while replacing 19 feet of main across the creek.	05/08/13	05/08/13	Creek crossing repaired on 5-9-13 by installation of new line and casing.		
63	5/13/2013	10:44	n		9,240	4776 Snapfinger Woods Drive	Decatur	008-s004	8	GR	Grease blocked 8 inch main	Snapfinger Creek	N	5/13/2013	13:18	After attempting to rod line it was pressure washed 160 feet to clear blockage and restore flow.	05/13/13	05/14/13		In wetlands mitigation bank project under engineering process to secure permits and easements to clean system.	
64	5/15/2013	9:46	n		3,540	4430 Old Lake Drive	Decatur	034-s013	8	GR	Grease blocked 8 inch main	Snapfinger Creek	Y	5/15/2013	10:45	Pressure washed line 500 feet to remove blockage at 250 feet and restored flow.	05/16/13	05/16/13			
65	5/21/2013	8:19	n	YES	12,540	3732 Cherry Ridge Blvd	Decatur	060-s055	8	GR	Grease blocked 8 inch line	South River	U	5/21/2013	11:48	Pressure washed main from 060-s049 upstream 510 feet to remove blockage at 327 feet and restored flow.	05/21/13	05/22/13		This report contains correct information from all updates.	
66	5/25/2013	15:58	n		7,100	6631 Hillandale Drive	Lithonia	119-s020	10	GR	Grease blocked line	Stewart Lake	L	5/25/2013	17:09	Pressure washed main 300 feet and cleared blockage at 173 feet to restore flow.	05/26/13	05/29/13			
67	5/29/2013	20:15	n		700	2305 Varkel Way	Lithonia	NA	10	BRK LN/STR	Crack in bottom of 10 inch creek crossing	Pole Bridge Creek	Y	5/29/2013	22:35	Put a repair clamp on line to stop leak.	05/30/13	05/31/13			
68	6/1/2013	19:57	n		6,180	4371 Winters Chapel Road	Doraville	340-s004	8	GR	Grease blocked 8 inch main	Nancy Creek	2	6/1/2013	21:40	Pressure washed 8 inch main 400 feet and cleared blockage at 30 feet from 340-s005 to restore flow.	06/02/13	06/03/13			
69	6/4/2013	9:09	n		7,860	1703 Glencove Avnue SE	Atlanta	180-s201	8	GR	Grease blocked 8 inch sewer min.	Sugar Creek	A	6/4/2013	11:20	Pressure washed 8 inch main downstream 315 feet from 180-s201 and removed blockage at 245 feet to restore flow.	06/04/13	06/05/13			
70	6/4/2013	9:21	n	YES	10,780	5083 Biffle Road	Stone Mountain	028-s016	10	RT	Roots blocked 10 inch sewer line	Snapfinger Creek	U	6/4/2013	11:55	After initial attempt at rodding failed the line was pressure washed and root cut 568 feet to remove blockage at 218 feet upstream from 028-s077 to restore flow.	6-4-13	06/05/13			
71	6/4/2013	16:47	n		4,230	5101 Panola Industrial Blvd	Decatur	024-s036 and 037	12	GRDB	Grease and small rocks blocked 12 inch line causing 2 manholes on 8 inch line to overflow.	Panthers Branch Creek	N	6/4/2013	19:08	Pressure washed 12 inch line 700 feet upstream from 023-s082 and cleared blockage at 275 feet.	06/05/13	06/05/13	Offset joint under I-20 and add to routine cleaning list		
72	6/6/2013	11:51	n		8,280	3851 West Nancy Creek Place	Atlanta	NA	8	CRK BRK	8 inch creek crossing washed out from storm	Perimeter Creek	U	6/6/2013	18:45	Repaired creek crossing and restored bank erosion protection.	06/07/13	06/11/13		Dispatch delayed reporting to field crew to be addressed by disciplinary action.	
73	6/12/2013	14:24	n		4,640	854 Shepard Road	Stone Mountain	073-s038	8	GRRTDB	Grease, roots and rags blocked the 8 inch main.	Barbashela Creek	N	6/12/2013	16:20	Pressure washed the main 680 feet to clear blockage at 75 feet and restore flow.	06/12/13	06/13/13	Add to Root Control List		
74	6/18/2013	10:13	n		940	2957 Belvedere Lane	Decatur	200-s072	8	GR	Grease blocked main	Shoal Creek	U	6/18/2013	11:00	Attempted to rod main unsuccessfully and pressure washed main 1400 feet to remove blockage at 412 feet.	06/18/13	06/19/13		Correct volume is 940 gallons and not 970 as reported. Calculation Error.	
75	6/24/2013	8:40	n		7,400	1817 Clifton Road	Atlanta	057-s008	8	GR	Grease blocked main	South Fork Peachtree Creek	N	6/24/2013	11:45	Attempted to rod main 60 feet and had to pressure wash main 389 feet to remove blockage at 60 feet and restore flow.	06/25/13	06/25/13			

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Spills that Entered Waters of the US/State

SSO NO.	Date/Time		Type & Volume		Location		MH/Line		Cause/Source		Water Body			Flow Restoration			Notification Dates			Update Comments
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole/Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up	Comments
76	6/24/2013	9:42	n		3,240	4486 Mercer Road	Decatur	194-s064 and s065	8	GR	Grease blocked main	Snapfinger Creek	N	6/24/2013	10:36	Pressure washed main 170 feet to clear blockage at 40 feet and restore flow.	06/25/13	06/25/13		
77	6/24/2013	13:19	n		9,660	2603 Rockcliff Road	Atlanta	116-s201	8	GR	Grease blocked main	Sugar Creek	N	6/24/2013	16:00	Pressure washed main 300 feet to remove blockage at 221 feet and restore flow.	06/25/13	06/25/13		

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Building Back-up Report

Building Back-up #	Date/Time		Quantity in Gallons (est.)	Location		Cause/Source		Flow Restoration			Number	Actions				
	Date Spill Reported to DWM	Time Spill Reported to DWM		Address of Spill	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action	Service Request	Cleaning Service	Inspection Results	Additional Follow-up	Faulty Home Plumbing or Not to Code	Update Comments
B08-13	04/02/13	11:22	10	2320 Crestcliff Drive	Tucker	DB	Tissue blocked 8 inch main.	04/02/13	14:30	Rodded main 75 feet to remove tissue and restore flow.	1315011	No	Pressure washed and root cut main 200 feet to remove rocks, sand and roots. CCTV of 800 feet showed no defects.		YES	Customer did not have property line cleanout.
B09-13	04/11/13	18:45	20	3700 Wittenburg Court	Decatur	DB	Rags blocked main	04/11/13	20:00	Pressure washed 8 inch main 100 feet to remove blockage at 50 feet.	1316452	No	CCTV 400 feet of main and root cut 320 feet. Main is in good condition and flowing.	Surface spill S28-13	X	Customer refused cleaning service since sewer only in bathtub.
B10-13	04/16/13	11:05	250	2860 McClave Drive	Doraville	OTH	Flow meter control box blocked 10 inch main causing surcharged lines.	04/16/13	13:05	Pressure washed 10 inch main 180 feet, found and removed flow monitor control box from manhole.	1316933	Yes	CCTV sewer main 370 feet and no defects found.	Health Department notified on 5-6-13 about defective house plumbing and sewer under house.	YES	Defective home owner plumbing under house caused spill in crawlspace and just outside building.
B11-13	04/21/13	22:19	250	2613 Lewfield Circle	Decatur	GRDB	Grease, bricks and a piece of rebar blocked line.	04/21/13	23:10	Rodded 8 feet from MH 114-s010 to clear blockage and restore flow, removed rebar and pressure washed MH to MH 208 feet.	1317748	Yes	CCTV main 200 feet and found no defects.		YES	No backflow device present despite letter being sent.
B12-13	03/03/13	12:07	20	1118 Redan Trail Court	Stone Mountain	UNK	Main line blocked by unknown item.	03/03/13	14:30	Pressure washed main 175 feet to clear blockage.	1309889	No	CCTV 300 feet and found no defects. Main is clear at this time.		X	Customer called own cleaning service
B13-13	05/10/13	10:03	2,340	3534 Misty Valley Road	Decatur	GR	Grease blocked 8 Inch line causing manhole surcharge	05/10/13	10:42	Pressure washed main 200 feet to restore full flow.	1320845	Yes	CCTV 130 feet and root cut the main to remove heavy grease and roots. Main is clear at this time.		YES	Faulty plumbing under house allowed sewage to escape into crawl space only.
B14-13	05/11/13	16:11	1,800	2910 Redding Road	Atlanta	GR	Grease blocked 8 inch line causing surcharge and subsequently back-up into home.	05/11/13	18:20	Pressure washed main 237 feet to restore flow	1320997	No	CCTV and root cut 450 feet to remove mild roots. Main is clear at this time.		YES	Customer sent 2nd backwater valve letter after first one sent in 2010.
B15-13	5/19/2013	18:09	10	3556 Montreal Way	Tucker	GR	Grease blocked 8 Inch line causing surface spill and building back-up.	05/19/13	20:45	Pressure washed main 703 feet to remove blockage at 71 feet and restore flow.	1322093	No	CCTV 145 feet and pressure washed/root cut main 944 feet. Main is clear at this time.		YES	Customer ignored backwater valve letter.
B16-13	5/20/2013	10:45	50	3895 Snapfinger Road	Lithonia	GRRT	Blocked 8 inch main and crew blew water in the building trying to unstop.	05/20/13	16:55	Root cut main, got it stuck at 80 feet at 16:00, blew water in the house and finally freed root cutter to restore flow at 16:55	1322296	Yes	CCTV main 377 feet. Pressure washed 690 feet to remove rocks and sand. Main is clear at this time.		YES	Sent backwater valve letter
B17-13	5/20/2013	20:33	50	2330 Emerald Falls Drive	Decatur	GR	Grease blocked 8 inch sewer main	05/20/13	22:50	Pressure washed main 145 feet downstream from 2318 Emerald Falls to restore flow.	1322273	No	CCTV main 239 feet downstream and pressure washed/root cut 265 feet upstream. Main is clear at this time.		YES	Sent backwater valve letter
B18-13	5/24/2013	15:52	20	3895 Snapfinger Road	Lithonia	OTH	See B16-13 as carryover for house lines	05/24/13	18:00	Did not witness spill but could be carry-over from B16-13 event.	1323017	Yes	Order issued and completed 5-25-13		NA	
B19-13	5/25/2013	20:15	10	3895 Snapfinger Road	Lithonia	OTH	See B16-13 as carryover for house lines	05/25/13	23:30	Customer called again claiming issue from B16-13. Had plumber go to clean interior plumbing.	1323076	Yes	CCTV 377 feet and removed rocks and sand.	No exterior issue. Plumber cleaned line connecting washing machine.	NA	Check valve installed and interior flowing now.
B20-13	6/7/2013	9:32	100	2920 Townley Circle	Doraville	RT	Roots blocked sewer main.	06/07/13	10:35	Pressure washed 8 inch main 245 feet upstream to 264-s073 to remove root blockage at 82 feet and restore flow.	1324877	Yes	CCTV 573 feet upstream and pressure washed/root cut 800 feet. Main is clear at this time.		YES	Sent backwater valve letter.
Those items coded with the same number and different letter are the same event																

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Overflow (Surface Spills)

Overflow #	Date/Time		Quantity in Gallons	Location		Cause/Source		Flow Restoration			Number Service Request	Results	
	Date Spill Reported to DWM	Time Spill Reported to DWM		Address of Spill	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action		Inspection Results	Update Comments
S22-13	04/01/13	14:11	25	1845 Poplar Fallo Drive	Lithonia	VAND	Tires and plywood blocked manhole causing it to overflow.	04/04/13	15:00	Removed debris from manhole to restore flow.	1314851		
S23-13	04/02/13	13:42	100	4034 Flakes Mill Road	Decatur	RT	Heavy roots blocked 8 inch main	04/02/13	16:32	Rodded main 10 feet to remove heavy roots.	1315035	CCTV and root cut 800 feet of line with no defects noted.	
S24-13	04/03/13	12:30	40	4995 Flat Shoals Parkway	Decatur	DB	Debris (concrete and asphalt) from road repaving blocked main	04/03/13	12:30	Vacuumed debris out of manhole to restore flow	1315216	County Inspector to verify other manholes were not used for debris disposal.	
S25-13	04/07/13	13:16	1,100	3052 Margavera Terrace	Atlanta	GRRT	Grease and roots blocked main.	04/07/13	14:09	Pressure washed 8 inch main 150 feet and removed blockage at 120 feet.	1315727	CCTV and pressure washed 366 feet of main.	
S26-13	04/08/13	8:51	50	2375 Cranbrooke Drive	Decatur	GRRT	Grease and roots blocked main.	04/08/13	10:25	Pressure washed 8 inch main 350 feet and cleared blockage at 100 feet.	1315783		Root cut main 500 feet to clear line.
S27-13	04/09/13	17:17	260	2091 Cherry Lane	Decatur	RT	Roots blocked main	04/09/13	19:15	Pressure wahsed 8 inch main 200 feet to clear blockage at 100 feet.	1316120	CCTV and root cut 646 feet of main with no defects found.	
S28-13	04/11/13	18:45	3	3700 Wittenburg Court	Decatur	DB	Rags blocked 8 inch main.	04/11/13	20:00	Pressure washed main 100 feet to remove blockage at 50 feet.	1316452		See also B09-13.
S29-13	04/16/13	11:00	5	951 Oak Springs Court	Stone Mountain	RTDB	Roots and wipes blocked 6 inch cleanout	04/16/13	12:15	Rodded 6 inch cleanout 30 feet to remove roots and debris to restore flow.	1316932	CCTV 332 feet and found no defects.	Cleanout repaired 4-22-13
S30-13	04/18/13	12:50	5	1046 Willivee Drive	Decatur	GRDB	Lateral blocked with wipes, napkins and grease	04/18/13	16:00	Rodded lateral 36 feet to remove wipes, napkins and grease. Sewage spilled when cap removed to investigate.	1317345	CCTV 430 feet up and downstream from site and found no defects.	
S31-13	04/18/13	16:06	70	2567 Candler Woods Drive	Decatur	GRRT	Grease and roots blocked main.	04/18/13	18:00	Rodded 8 inch main 123 feet to restore flow followed by pressure washing 175 feet.	1317423	Reviewing for cleaning frequency.	
S32-13	05/01/13	7:54	18	2142 Johnson Ferry Road	Brookhaven	GRDB	Grease and Rags blocked line	05/01/13	12:21	Rodded 8 inch main 30 feet to restore flow	1319462	CCTV 675 feet upstream and found no defects.	
S33-13	05/01/13	14:31	5	3819 Landgraf Cove	Decatur	BRK LN/STR	Broken line blocked with paper.	05/01/13	18:00	Attempted rodding but needs point repair	1319368	CCTV 110 feet down stream and found no defects with line. Repaired stub on 5-2-13.	
S34-13	05/03/13	12:07	1,740	2892 Eastwyck Circle	Decatur	GR	Grease blocked 8 inch line	05/03/13	12:36	Rodded main 6 feet downstream and restored flow	1319726	CCTV and root cut main 120 Feet and found no defects.	
S35-13	05/04/13	18:23	4,000	1676 Fraizer Road	Decatur	STORM	Heavy Rain	05/05/13	0:26	Wait for rain to subside	1319831	Under Review	
S36-13	05/05/13	9:19	3,500	1440 Sowell Estates	Stone Mountain	STORM	Heavy rain	05/05/13	13:43	Wait for rain to subside	1319865	Determine if broken cleanout is real problem.	Get with engineering to review this location and changes made from project in area.
S37-13	05/05/13	10:00	1,125	8648 Covington Highway	Lithonia	STORM	Storm caused power failure	05/05/13	1:30	Station restarted when power returned.	1329627		
S38-13	05/10/13	9:54	2,720	1568 Clairmont Lane	Atlanta	GRDB	Grease and Rags blocked line	05/10/13	12:10	Pressure washed 8 inch main 120 feet to restore flow.	1320842	Root intrusion in joints	Add to root control list.
S39-13	05/11/13	16:03	1,540	473 Rays Road	Stone Mountain	GR	Grease blocked 8 inch main	05/11/13	17:20	Rodded 8 inch main 96 feet to restore flow	1320996	Pressure washed main 400 feet to remove sand and rocks. CCTV 615 feet and sewer is clear and flowing.	
S40-13	05/11/13	19:50	1,320	1568 Clairmont Lane	Atlanta	GR	Grease and Rags blocked line	05/11/13	20:56	Pressure washed main 250 feet to remove grease and rags to restore flow.	1321011	CCTV 400 feet and noted root protusion in joints.	Add to root control list.
S41-13	05/13/13	9:15	4,200	4503 Dogwood Farms Drive	Decatur	GR	Grease blocked 8 inch main	05/13/13	10:25	Pressure washed main 500 feet to remove blockage at 80 feet to restore flow.	1321094	CCTV 200 feet and found heavy grease and roots which were removed.	

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Overflow (Surface Spills)													
Overflow #	Date/Time		Quantity in Gallons	Location		Cause/Source		Flow Restoration			Number	Results	
	Date Spill Reported to DWM	Time Spill Reported to DWM		Address of Spill	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action	Service Request	Inspection Results	Update Comments
S42-13	05/19/13	18:09	3,120	3556 Montreal Way	Tucker	GR	Grease blocked 8 Inch main.	05/19/13	20:45	Pressure washed main from MH 144-s056 703 feet to remove blockage at 71 feet and restore flow.	1322093	Pressure washed and CCTV 673 feet of 8 inch sewer main. Main is clear and flowing.	
S43-13	05/22/13	11:20	100	2703 Knollberry Lane	Decatur	GR	Grease blocked 8 inch main causing 4 inch private cleanout to overflow.	05/22/13	12:45	Pressure washed 8 inch sewer main 600 feet to remove blockage at 347 feet and restore flow.	1322602	CCTV 270 feet and found roots and grease which were removed.	Add to root control list.
S44-13	05/27/13	19:38	20	847 Needle Rock Drive	Stone Mountain	GR	Found manhole surcharging and leaking around ring	05/27/13	20:05	Cleared grease blockage in manhole with goosneck to restore flow.	1323176	CCTV 458 feet and found root problem at 13 feet requiring repair. Made repair on 6-4-13.	
S45-13	06/07/13	12:16	2,760	112 East Maple Street	Decatur	OUTSIDE CON	Contractor improperly bypassed a manhole and caused a spill upstream.	06/07/13	13:02	Pressure washed 235-s202 15 feet to restore flow and had contractor remove 4 inch HDPE drain pipe from 8 inch line and repair invert properly.	1324896		Not a County contractor
S46-13	06/09/13	9:05	150	534 Penny Lake Lane	Stone Mountain	GR	Grease plugged air relief valve.	06/09/13	10:18	Lift Station crews repaired ARV after the manhole was vacuumed out to stop the spill.	1325016		
S47-13	06/10/13	19:00	4	2949 Greenoaks Circle	Atlanta	GR	Grease blocked 8 inch main.	06/10/13	22:00	After attempting to remove the blockage with rods we pressure washed the 8 inch sewer main 300 feet and cleared blockage at 150 feet to restore flow.	1325226	Manhole issues fixed 7-15-13	
S48-13	06/24/13	20:10	35	1079 Park Gate Place	Stone Mountain	GRRT	Grease and roots blocked 8 inch main.	06/24/13	21:50	Rodded main 90 feet to remove blockage and then pressure washed 175 of main to restore flow.	1327287		